


CONCRETE FOOTER TO BELOW LOCAL FROST LEVEL OR LOCAL CODE.

(4) 5/8" DIA. X 18" LONG ZINC PLATED STEEL ANCHOR BOLTS.



BOTTOM VIEW

1=8

Drawing for illustration only - scale approximate

NOTE:
 TO CONVERT LANTERN TO H.I.D., ORDER ACCESSORY #056 WITH 50, 75 WATT M.V., 35, 50, 70 WATT H.P.S., OR 50, 70 WATT M.H. (SPECIFY VOLTAGE)
 LANTERN WILL BE PREWIRED AND TESTED.
 ALL ELECTRICAL COMPONENTS ARE U.L. LISTED.
 ALL MOUNTING HARDWARE IS SUPPLIED.

APPROVAL SIGNATURE:		FINISH:	BALLAST: <input type="checkbox"/> Mercury Vapor <input type="checkbox"/> Metal Halide <input type="checkbox"/> High Pressure Sodium		TITLE: SMALL NAUTICAL INCANDESCENT BOLLARD	
HEIGHT	41 3/4"	PANELS:			WATTAGE: VOLTAGE: POWER FACTOR: <input type="checkbox"/> NPF <input type="checkbox"/> HPF	425 E. MIDDLE ST. HANOVER PA 17331 PH: (717) 632-6464 - FAX: (717) 699-2930
WIDTH	13 1/8" DIA.	SOCKET:		SCALE: 1=4	DATE: 11/23/04	DWG. BY: TLS
PROJECTION		<input type="checkbox"/> MEDIUM <input type="checkbox"/> MOGUL				
TOP TO OUTLET						